

August 9, 2022

Johnson County Planning & Zoning
86 W. Court Street
Franklin, IN 46131




RE: Center Grove High School
Softball & Golf Facility
Drainage Narrative

Please accept the enclosed plans for drainage approval of the above referenced project. Included within this project is the construction of a +/- 10,000 square foot building that will be utilized as a training facility for the softball and golf student athletes. The proposed building was master planned within the project designed by Civil & Environmental Consultants, Inc. (CEC) in 2017 (see attached exhibit). During the previous design, it was anticipated that a future 10k sft building would be designed and constructed in the general location identified within the attached exhibit. The proposed drainage patterns shall maintain the existing drainage patterns, which convey a majority of the runoff northerly into the existing detention facility. No additional impervious area, or storm sewer infrastructure, is proposed for this project. Based on the previous drainage approval, which included the future building, it is anticipated that the proposed project will not have an adverse effect or overburden any downstream drainage facilities.

If you should have any questions or comments concerning this project, feel free to contact me at (317) 780-1555 ext 112.

Sincerely,

CrossRoad Engineers, PC

Gregory J. Ilko, P.E.
Vice President

